

NSF Product and Service Listings

These Listings were Last Updated on **Tuesday, November 14, 2006** at 4:15 AM Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Warning: NSF is concerned about fraudulent downloading and manipulation of website text. If you have received this listing in hard copy, always confirm this certification/listing information by going directly to <http://www.nsf.org/Certified/PwsComponents/Listings.asp?Company=3E440&Standard=061&> for the latest most accurate information.

NSF/ANSI STANDARD 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings](#).

PROCESS SOLUTIONS INC.

1077 DELL AVENUE
SUITE A
CAMPBELL, CA 95008
408-370-6540



Facility : CAMPBELL, CA

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Chemical Generators MicrOclor[1] [2]	[3]	CLD 23	MLTPL

[1] Certification is based on a sodium hypochlorite solution of 8,000 mg/L with a dosage rate yielding a maximum chlorine concentration of 10 mg/L into potable water.

[2] Certification of this product has been performed to the health effects requirements of NSF/ANSI Standard 61, which assesses the acceptability of potential extractants from the chemical generator. No evaluation has been performed on the strength or efficacy of the chemical(s) generated. As unit operation, maintenance and the consistency of source ingredients may affect the performance of the unit, the ensuing chemical(s) is not Certified by NSF to NSF/ANSI Standard 60.

[3] Certified for the following usage rates: 20 lb/day, 40 lb/day, 60 lb/day, 80 lb/day, 100 lb/day, 200 lb/day, 300 lb/day, 600 lb/day, 900 lb/day and 1200 lb/day.